

Type Approval Certificate Extension

This is to certify that Certificate No. 01/10035 for the undernoted products is extended and renumbered as shown.

This certificate is issued to:

PRODUCER	Kuk Dong Level Co.
PLACE OF PRODUCTION	843-1, Janglim-Dong, Saha-ku, Busan 604-842, Korea
DESCRIPTION	Level switches
TYPE	KD-12 series KD-30 series KD-90 series KD-100R series
APPLICATIONS	Marine and offshore applications for environmental categories ENV2 and ENV4 as defined in LR's Test Specification No.1-1996.
ADDITIONAL TEST	High temperature test at 70°C for 2 hours and at 120°C for 30 minutes.

"This Certificate is not valid for equipment, the design, ratings or operating parameters of which have been varied from the specimen tested. The manufacturer should notify Lloyd's Register Asia of any modification or changes to the equipment in order to obtain a valid certificate."

The attached Design Appraisal Document No. 01/10035 (E1) and its supplementary Type Approval Terms and Conditions form part of this Certificate.

All other details remain as the previous Certificate No. 01/10035 to which this extension should be attached.

Certificate No.	01/10035 (E1)
Issue Date	31 May 2006
Expiry Date	30 May 2011
Sheet	1 of 1



T. Sato
Yokohama Design Support
& Plan Approval Department
Lloyd's Register Asia

Lloyd's Register Asia, registered office:
71 Fenchurch Street, London EC3M 4BS